

Alexander, Kerry

From: UNITED TEACHERS OF LOWELL <utl@utlowell495.org>
Sent: Thursday, March 07, 2019 4:22 PM
To: Alexander, Kerry
Cc: Paul Georges
Subject: LPS Schools

BOH
4-3-19

Hi Kerry,

This is what we received regarding LPS schools....

BUILDING ISSUES
March 6, 2019 –

BARTLETT

Mar. 6, 2019 Mice droppings in room 36 – Banner Pest Control has been notified.

LOWELL HIGH

Mar. 6, 2019 No heat this morning in room 105 this morning. The current temperature is 50 degrees and there is no heat coming in. Valve in my room was checked and it is open.

Mar. 7, 2019 Received report of no heat in sections 100, 200 & 300. Burst pipes in basement – students in the Little Theater. Teachers using doors to hold up ceiling tiles.

Roxanne's response to inquiry - Just to keep you in the loop. At some point the air circulating pump or the condenser went down overnight. That is why we walked into a cold building. Everything is working and the heat is gradually making its way through the system. So the good news is that the two boilers that so much time and effort went in to fixing are working, the bad news is other components in the system were not. When the system goes down and comes back on it causes condensation in the pipes, that is why we walked in to leaks in the basement.

Room 101 – 42 degrees

Thank you,
Nancy