

# Lowell Regional Water Utility

815 Pawtucket Blvd., Lowell, MA 01854

## 2019 Annual Water Quality Report

Volume 22

PWS ID # MA 3160000

### ~ OUR PRIDE FLOWS ~

**Dear Consumer:** The Lowell Regional Water Utility (LRWU) is proud of the fine drinking water it provides to the residents of Lowell and to several of our neighboring communities. We are pleased to present a summary of the quality of the water provided to you during the calendar year 2019. The USEPA 1996 Safe Drinking Water Act (SDWA) requires that all utilities across the country issue an annual “Consumer Confidence Report” to their customers in addition to other notices that may be required by law. This report details where our water comes from, what it contains, and the possible risks to the health of certain segments of the population. Our constant water testing and the continuously updated treatment plant are designed to insure that we are providing you with the safest and most reliable water supply. We encourage public interest and participation in our community's decisions affecting drinking water. Informed consumers are our best allies in maintaining safe drinking water. All requests for information or any questions regarding this Water Quality Report should be directed to Steven Duchesne, Superintendent of Operations, at 978-674-1677, or Fax at 978-970-4235.

**From the desk of Steven Duchesne, Operations Superintendent:** Over the last two decades, the Lowell Regional Water Utility’s (LRWU’s) primary focus has been to improve the quality, pressure and reliability of the City’s water supply. We have performed numerous upgrades to the treatment plant and distribution system, each of which was required to satisfy regulatory requirements and improve water service to consumers. I am proud to report that the City of Lowell continues to provide residents with the highest water quality at one of the lowest rates in the Commonwealth at \$2.13 per hundred cubic feet(HCF). In fact, despite the significant amount of work performed on our water system in recent years, of over 270 communities and water systems in Massachusetts, our water rates continue to be in the lowest 5% in the state. Today, the LRWU is continuing its focus on improving water service to the consumer population it serves. Recently completed projects and new projects currently underway will further improve the quality, pressure, and reliability of the water we deliver to consumers. We are also continuing to improve the overall efficiency of the water treatment plant and pumping operations. These projects include improvements to the distribution system, pumping stations, metering, and water treatment plant. Each of these projects is critical to the LRWU’s ongoing effort to reliably deliver high quality water for many years to come.

### Overview:

In 2019, the LRWU purified more than 4.1 billion gallons (4,167,000,009) of drinking water delivered to approximately 135,000 residents and businesses in the communities of Lowell, Dracut, Tewksbury, Tyngsboro, and Chelmsford. **Lead and Copper:** The annual monitoring rounds of lead and copper “tap sampling” were performed for the years 2000, 2001, 2002, and 2003. In all required compliance testing rounds, the 90<sup>th</sup> percentile action level for lead (0.015 mg/l) and copper (1.3 mg/l) were not exceeded, and haven’t since. The next rounds of lead and copper sample monitoring will be collected during summer 2020.

**An Explanation of the Water-Quality Data Table:** Unless otherwise noted, this report is based upon tests conducted in the year 2019 by the Lowell Regional Water Utility’s certified Laboratory Director, Treatment Plant Operators, and by certified water-testing laboratories. Terms used in the Water-Quality Table and in other parts of this report are defined here.

**Maximum Contaminant Level - (MCL):** The highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG’s as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal - (MCLG):** The level of a contaminant in drinking water below, which there is no known or expected risk to health. MCLG’s allow for a margin of safety.

**Maximum Residual Disinfectant Level - (MRDL):** The highest level of a disinfectant (chlorine) allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal - (MRDLG):** The level of a drinking water disinfectant (chlorine) below, which there is no known or expected risk to health. MRDLG’s do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Action Level - (AL):** The concentration of a contaminant that, if exceeded, triggers a treatment or other requirement, which a water system must follow.

**Treatment Technique - (TT):** A required process intended to reduce the level of a contaminant in drinking water.

### Key to Table:

ppm = parts per million, or milligrams per liter (mg/l)

ppb = parts per billion, or micrograms per liter (µg/l)

ppt = parts per trillion

pCi/l = picocuries per liter (a measure of radioactivity)

TT = Treatment Technique

AL = Action Level

N/A = Not Applicable

MDL = Method Detection Limit

ORSG = Office of Research and Standards Guideline

MRDL = Maximum Residual Disinfectant Level

MRDLG = Maximum Residual Disinfectant Level Goal

< > = less than or greater than

MCL = Maximum Contaminant Level

MCLG = Maximum Contaminant Level Goal

NTU = Nephelometric Turbidity Units

N/D = Non-Detectable

90<sup>th</sup> % = Out of 10 homes, 9 were at or below this level

## 2019 Water Quality Data Table

Contaminant Detected	Unit	MCL	MCLG	Level Detected	Range of Detection	Major Sources	Violation
<b>Regulated Contaminants</b>							
Nitrate	ppm	10	10	0.214	0.214	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion from natural deposits.	NO
Fluoride * (see below)				0.84	0.51 to 0.84	Water additive which promotes strong teeth.	NO
* State (MCL)	ppm	2	none				
* EPA (MCL)	ppm	4	none				
Sodium	ppm	none	none	33.0	33.0	Erosion of natural deposits; road salt and water treatment chemicals.	NO
Chlorite	ppm	1.0	0.8	0.37	0.09 to 0.37	By-product of drinking water disinfection.	NO
Turbidity (see note)	NTU	1.0	TT= 100 %	0.19	0.02 to 0.19	Soil runoff.	NO
TT = lowest percentage of monthly samples < 0.3 NTU							
<b>Note:</b> Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.							
Disinfectant residual	ppm (MRDL)	4	(MRDLG) 4	1.17	0.74 to 1.17	By-product of drinking water disinfection.	NO
Perchlorate	ppb	2.0	none	0.39	0.39	Rocket propellants, fireworks, munitions, flares, blasting agents. Aged water treatment disinfection chemicals.	NO
<b>Volatile Organic Contaminants</b>							
(TTHM) [Total Trihalomethanes]	ppb (Highest Running Annual Average)	80	0	(47)	20 to 47	By-product of drinking water chlorination.	NO
<b>Disinfection By-Product Contaminants</b>							
(HAA) [Halo-acetic Acids]	ppb (Highest Running Annual Average)	60	0	(11)	3.8 to 11.0	By-product of drinking water chlorination.	NO
<b>Unregulated Contaminants</b>							
MTBE	ppb	none	none	N/D	N/D < 0.5	Gasoline Additive.	NO
Chloroform	ppb	none	none	14.6	5.8 to 14.6	By-product of drinking water chlorination.	NO
Bromodichloromethane	ppb	none	none	5.7	1.4 to 5.7	By-product of drinking water chlorination.	NO
Sulfate	ppm	none	none	3.0	3.0	Mineral and nutrient	NO
<u>PFAS (Per-and Polyfluoroalkyl substances including PFOS and PFOA)</u>							
<b><u>ORSG</u></b>							
Perfluorooctane Sulfonic Acid (PFOS)	ppt	none	20 ppt	1.2	1.0 to 1.3	Surfactant or emulsifier; used in fire-fighting foam, circuit board etching acids, alkaline cleaners, floor polish, and as a pesticide active ingredient for insect bait traps; U.S. manufacture of PFOS phased out in 2002; however, PFOS still generated incidentally and in some older products.	NO
Perfluorooctanoic Acid <sup>1</sup> (PFOA)	ppt	none	20 ppt	2.4	1.9 to 2.9	Perfluorinated aliphatic carboxylic acid; used for its emulsifier and surfactant properties in or as fluoropolymers (such as Teflon), fire-fighting foams, cleaners, cosmetics, greases and lubricants, paints, polishes, adhesives and photographic film	NO
Perfluorohexanesulfonic <sup>1</sup> (PFHxS)	ppt	none	20 ppt	< 2.0	N/D < 2.0	Manmade chemical; used in products to make them stain, grease, heat and water resistant	NO
Perfluoroheptanoic Acid <sup>1</sup> (PFHpA)	ppt	none	20 ppt	1.0	0.79 to 1.3	Manmade chemical; used in products to make them stain, grease, heat and water resistant	NO

## 2019 Water Quality Data Table cont'd

Contaminant Detected	Unit	MCL	MCLG	Level Detected	Range of Detection	Major Sources	Violation
<b>Unregulated Contaminants</b>							
<u>PFAS (Per-and Polyfluoroalkyl substances including PFOS and PFOA)</u>							
			<b>ORSG</b>				
Perfluorononanoic Acid <sup>1</sup> (PFNA)	ppt	none	20 ppt	< 2.0	N/D < 2.0	Manmade chemical; used in products to make them stain, grease, heat and water resistant	NO
Perfluorodecanoic Acid (PFDA)	ppt	none	20 ppt	0.95	0.95 to < 2.0	Manmade chemical; used in products to make them stain, grease, heat and water resistant	NO
<p>There is currently no drinking water standard for PFAS as a group by the US Environmental Protection Agency (USEPA). USEPA has set Health Advisories for two PFAS compounds, PFOA and PFOS. Based on chemical similarities, MassDEP considers four other PFAS compounds, PFNA, PFHxS, PFHpA and PFDA, to be of similar concern and has established an Office of Research and Standard Guideline (ORSG) for these six PFAS as a group.</p>							
<p>Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining their occurrence in drinking water and whether future regulation is warranted.</p>							
<b>Radionuclides</b> next round of testing 2023							
Gross Alpha	pCi/l	15	0	0.04 (+-0.6)	N/A	Erosion of natural deposits	NO
Radium 228	pCi/l	5	0	- 0.20 (+-0.6)	N/A	Erosion of natural deposits	NO
Contaminant	Unit	AL	MCLG	90 <sup>th</sup> % Value	# of Samples Above AL	Major Sources	Violation
Lead	ppb	15	0	.001	1 of 50	Corrosion of household plumbing systems. Erosion of natural deposits;	NO
Copper	ppm	1.3	1.30	.029	0 of 50	Corrosion of household plumbing systems. Erosion of natural deposits; Leaching from wood preservatives	NO

Finished water pH 7.7 to 8.1

### Water Source:

The only water supply for Lowell's Water Treatment Plant is the surface water from the Merrimack River, which has its source in the White Mountains of New Hampshire. The Intake Station is situated on the riverbank north of the city and water is pumped one half mile to the treatment plant. The interconnections with the surrounding communities are to supply them with water; they cannot supply water to Lowell. A draft source water assessment (**SWAP**) was completed by the Massachusetts DEP. The (SWAP) report is available at the water utility for any parties interested.

A susceptibility ranking of High was assigned to this system using the information collected during the assessment by the DEP. As with many water systems, this watershed contains potential sources of contamination. However, source protection measures reduce the risk of actual contamination. The Lowell Regional Water Utility was commended for taking an active role in protecting their drinking water source. Some examples of the staff's good work include the following:

**Emergency Planning and Response** – The Utility works with upstream communities in Massachusetts and New Hampshire on emergency response planning. The City has an emergency management committee and has coordinated activities with the Massachusetts Emergency Management Agency (MEMA).

**Communication with Other Communities** – The Utility maintains contact with upstream and downstream communities, including those in New Hampshire, on a variety of source protection issues.

## Unregulated Contaminants:

Our utility participated in a major drinking water quality-testing program in 1998 called the **Information Collection Rule (ICR)**. One of the contaminants we tested for is the parasite *Cryptosporidium* which has caused outbreaks of intestinal disease in the U.S. and overseas. *Cryptosporidium* is the only contaminant for which source water monitoring results must be reported. It is common in surface water, very hard to kill, and even a well-run water system will contain some live parasites. The U.S. Environmental Protection Agency (EPA) is working to resolve several scientific issues that will allow it to set *Cryptosporidium* safety standards. Our testing, performed quarterly in 1998 on the river water, revealed the presence of *Cryptosporidium*, but no precaution about our drinking water is currently needed for the general public, since **Cryptosporidium was not found in the finished treated drinking water that goes to your tap!**

## Required Educational Information:

Drinking water, *including bottled water*, may reasonably be expected to contain at least small amounts of some contamination. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about potential health effects of their drinking water from their health care providers. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in *bottled water* that must provide the same protection for public health. Contact the EPA's Safe Drinking Water Hotline (800-426-4791) for more information about contaminants and potential health effects; and EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants.

☐ **Perchlorate** - Perchlorate interferes with the normal function of the thyroid gland and thus has the potential to affect growth and development, causing brain damage and other adverse effects, particularly in fetuses and infants. Pregnant women, the fetus, infants, children up to the age of 12, and people with a hypothyroid condition are particularly susceptible to perchlorate toxicity.

☐ **Fluoride** was added to prevent tooth decay/cavities.

☐ **Lead** - "If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Lowell Regional Water Utility is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline 1.800.426.4791 or at: <http://www.epa.gov/safewater/lead>.

## Contaminants that may be present in source water include:

The sources of drinking water (*both tap water and bottled water*) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

- (A) **Microbial contaminants;** such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) **Inorganic contaminants;** such as salts and metals, can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) **Pesticides and herbicides;** may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- (D) **Organic chemical contaminants;** include synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.
- (E) **Radioactive contaminants;** can be naturally occurring or be the result of oil and gas production and mining activities.

## CROSS-CONNECTION CONTROL AND BACKFLOW PREVENTION

The Lowell Regional Water Utility makes every effort to ensure that the water delivered to your home and business is clean, safe and free of contamination. Our staff works very hard to protect the quality of the water delivered to our customers from the time the water is extracted from the Merrimack River, throughout the entire treatment and distribution system. But what happens when the water reaches your home or business?

### What is a cross-connection?

A cross-connection occurs whenever the drinking water supply is or could be in contact with potential sources of pollution or contamination. Cross-connections exist in piping arrangements or equipment that allowed the drinking water to come in contact with non-potable liquids, solids or gases (hazardous to humans) in event of a backflow.

### What is a backflow?

Backflow is the undesired reverse of the water flow in the drinking water distribution lines. This can occur when the pressure created by an equipment or system such as a boiler or air-conditioning is higher than the water pressure inside the water distribution line (backpressure), or when the pressure in the distribution line drops due to routine occurrences such as water main breaks or heavy water demand causing the water to flow backward inside the water distribution system (back-siphonage).

### What can I do to help prevent a cross-connection?

- NEVER submerge a hose in soapy water buckets, pet watering containers, pool, tubs, sinks, drains or chemicals.
- NEVER attached a hose to a garden sprayer without the proper backflow preventer.
- Buy and install a hose bibb vacuum breaker in any threaded water fixture. The installation can be as easy as attaching a garden hose to a spigot. This inexpensive device is available at most hardware stores and home-improvement centers.
- Identify and be aware of potential cross-connections to your water line.
- Buy appliances and equipment with a backflow preventer
- Buy and install backflow prevention devices or assemblies for all high and moderate hazard connections.
- If you are the owner or manager of a property that is being used as a commercial, industrial or institutional facility you must have your property's plumbing system surveyed for cross-connection by your water purveyor. If your property has NOT been surveyed for cross-connection, contact your water department to schedule a cross-connection survey. For more information, please contact Thomas Laird at (978) 674-1683

Le rapport contient des informations concernant la qualité de l'eau de votre communauté. Faites-le traduire, ou parlez-en à un ami qui le comprend bien.

El informe contiene información importante sobre la calidad del agua en su comunidad. Tradúzcalo o hable con alguien que lo entienda bien.

O relatório contém informações importantes sobre a qualidade da água da comunidade. Traduza-o ou peça ajuda de uma pessoa amiga para ajudá-lo a entender melhor.

“នៅក្នុងរបាយការណ៍នេះមានព័ត៌មានសំខាន់ៗណាស់ ដែលទាក់ទងអំពីគុណភាពនៃទឹកច្រើននៅក្នុងសង្គមរបស់លោកអ្នក។ សូមបកប្រែរបាយការណ៍នេះឬក៏យកទៅជំរាញជាមួយមិត្តភក្តិព្រលោកអ្នកដែលយល់ពីរបាយការណ៍នេះបានច្បាស់ណាស់។”

Η έκθεση αυτή περιέχει σημαντικές πληροφορίες σχετικά με την ποιότητα του νερού της περιοχής σας. Εάν έχετε δυσκολία να καταλάβετε το περιεχόμενό της, παρακαλείσθε όπως ζητήσετε από γνωστούς ή φίλους σας να σας την μεταφράσουν.

**Lowell Regional Water Utility**  
**815 Pawtucket Blvd.**  
**Lowell, MA 01854**

“There’s a lot to like about Lowell” (2019 Water Quality Report)